

序号	报告编号	发布日期	结论	影像资料
175	GX-B1404/20-4-24015	2024. 5. 24	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
176	GX-B1404/20-4-24016	2024. 5. 24	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
177	GX-B1404/20-4-24017	2024. 5. 24	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

178	GX-B1404/20-4-24018	2024. 5. 24	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
179	GX-B1404/20-4-24019	2024. 5. 24	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
180	GX-B1321/20-4-24519~24527	2024. 5. 27	本次共检电力电缆9条，9条电力电缆所检项目合格。	

181	GX-B1321/20-4-24528~24534	2024. 5. 27	本次共检电力电缆7条，7条电力电缆所检项目合格。	
182	GX-B1321/20-4-24535~24541	2024. 5. 27	本次共检电力电缆7条，7条电力电缆所检项目合格。	
183	GX-B1321/20-4-24542~24549	2024. 5. 27	本次共检电力电缆8条，8条电力电缆所检项目合格。	


184	GX-B1321/20-4-24497~24502	2024/5/28	本次共检电力电缆6条，6条电力电缆所检项目合格。	 2024/5/12
185	GX-B1321/20-4-24503~24505	2024/5/28	本次共检电力电缆3条，3条电力电缆所检项目合格。	 2024/5/12
186	GX-B1321/20-4-24506~24513	2024/5/28	本次共检电力电缆8条，8条电力电缆所检项目合格。	 2024/5/13


187	GX-B1321/20-4-24514~24518	2024/5/28	本次共检电力电缆5条，5条电力电缆所检项目合格。	
188	GX-B1321/20-4-24550~24553	2024. 5. 28	本次共检电力电缆4条，4条电力电缆所检项目合格。	
189	GX-B1321/20-4-24554~24560	2024. 5. 28	本次共检电力电缆7条，7条电力电缆所检项目合格。	

190	GX-B1321/20-4-24561	2024. 5. 28	所检项目合格。	
191	GX-B1321/20-4-24562~24570	2024. 5. 28	本次共检电力电缆9条，9条电力电缆所检项目合格。	
192	GX-B1321/20-4-24571~24575	2024. 5. 28	本次共检电力电缆5条，5条电力电缆所检项目合格。	

193	GX-B1495/20-4-24997-241010	2024. 5. 29	所 本次共检高压开关柜14面，14面高压开关柜所检项目合格。	
194	GX-B1495/20-4-241011-241023	2024. 5. 29	本次共检防爆型高压配电装置13台，13台防爆型高压配电装置所检项目合格。	
195	GX-B1495/20-4-241125~241144	2024. 5. 31	本次共检高压防爆开关20台，20台所检项目合格。	


196	GX-B1495/20-4-241145~241156	2024. 5. 31	本次共检高压开关柜12面，12面高压开关柜所检项目合格。	
197	GX-B1495/20-4-241157~241172	2024. 5. 31	本次共检高压防爆开关16台，16台所检项目合格。	
198	GX-B1495/20-4-241060~241065	2024. 5. 31	本次共检防爆型高压配电装置6台，6台所检项目合格。	


199	GX-B1495/20-4-241066	2024. 5. 31	所检项目合格。	 2024. 4. 27
200	GX-B1495/20-4-241024~241037	2024. 5. 31	本次共检高压开关柜14面，14面高压开关柜所检项目合格。	 2024. 4. 24
201	GX-B1495/20-4-241038~241040	2024. 5. 31	本次共检高压开关柜3面，3面高压开关柜所检项目合格。	 2024. 4. 25

202	GX-B1495/20-4-241041~241047	2024. 5. 31	本次共检高压开关柜7面，7面高压开关柜所检项目合格。	
203	GX-B1495/20-4-241048~241059	2024. 5. 31	本次共检高压开关柜12面，12面高压开关柜所检项目合格。	
204	GX-B1495/20-4-241084~241086	2024. 5. 31	本次共检高压开关柜3面，3面高压开关柜所检项目合格。	


205	GX-B1495/20-4-241087~241093	2024. 5. 31	本次共检高压开关柜7面，7面高压开关柜所检项目合格。	 A worker in a blue uniform and red helmet is inspecting a high-voltage switchgear cabinet. The worker is holding a tool and looking at the equipment. The date stamp in the bottom right corner of the image is 2024. 4. 24.
206	GX-B1495/20-4-241094	2024. 5. 31	所检项目合格。	 A worker in a blue uniform and red helmet is inspecting a high-voltage switchgear cabinet. The worker is holding a tool and looking at the equipment. The date stamp in the bottom right corner of the image is 2024. 4. 24.
207	GX-B1495/20-4-241095~241106	2024. 5. 31	本次共检高压开关柜12面，12面高压开关柜所检项目合格。	 A worker in a blue uniform and red helmet is inspecting a high-voltage switchgear cabinet. The worker is holding a tool and looking at the equipment. The date stamp in the bottom right corner of the image is 2024. 4. 25.


208	GX-B1495/20-4-241107~241117	2024. 5. 31	本次共检高压开关柜11面，11面高压开关柜所检项目合格。	
209	GX-B1495/20-4-241118~241122	2024. 5. 31	本次共检高压开关柜5面，5面高压开关柜所检项目合格。	
210	GX-B1495/20-4-241123	2024. 5. 31	所检项目合格。	


211	GX-B1495/20-4-241124	2024. 5. 31	所检项目合格。	
212	GX-B1310/21-4-24027	2024. 5. 31	符合标准要求。	
213	GX-B1310/21-4-24028	2024. 5. 31	符合标准要求。	

214	GX-B1310/21-4-24029	2024. 5. 31	符合标准要求。	
215	GX-B1310/21-4-24049	2024. 5. 31	符合标准要求。	
216	GX-B1310/21-4-24050	2024. 5. 31	符合标准要求。	 

217	GX-B1310/21-4-24051	2024. 5. 31	符合标准要求。	
218	GX-B1310/21-4-24052	2024. 5. 31	符合标准要求。	
219	GX-B1310/21-4-24053	2024. 5. 31	符合标准要求。	

220	GX-B1310/21-4-24054	2024. 5. 31	符合标准要求。	
221	GX-B1495/20-4-241178~241180	2024. 5. 31	本次共检高压交流断路器3台，3台所检项目合格。	
222	GX-B1495/20-4-241181~241182	2024. 5. 31	本次共检高压交流断路器2台，2台所检项目合格。	

223	GX-B1495/20-4-241067~241075	2024. 5. 31	本次共检防爆型高压配电装置9台， 9台所检项目合格。	
224	GX-B1495/20-4-241076~241083	2024. 5. 31	本次共检防爆型高压配电装置8台， 8台所检项目合格。	
225	GX-B1310/21-4-240055	2024. 5. 31	符合标准要求。	

226	GX-B1332/21-4-24037~24039	2024/5/31	本次共检电力电容器3台，3台电力电容器所检项目合格。	
227	GX-B1547/20-4-24001~24003	2024/5/31	本次共共检继电保护装置3台，3台所检项目合格。	
228	GX-B1547/20-4-24004~24006	2024/5/31	本次共共检继电保护装置3台，3台所检项目合格。	

229	GX-B1328/20-4-24064	2024/5/31	本次共检验电器6支，6支所检项目合格。	
230	GX-B1328/20-4-24066	2024/5/31	本次共检便携式短路接地线6组，6组所检项目合格。	
231	GX-B1328/20-4-24067	2024/5/31	本次共检绝缘杆2组，2组所检项目合格。	